



---

## Reporting unsafe electrical installations

When electricians find an electrical installation that is unsafe, the *Occupational Licensing Act 2005* requires them to report it.

The safety issue may have come about due to defective electrical work, degradation of a previously compliant electrical installation or other works which may have made an installation non-compliant.

Electrical apprentices must report the issue to their supervisor, and electrical practitioners must inform their direct manager or the contractor's nominated manager. The other actions needed depend on the severity of the risk.

### **If there is an immediate risk of electric shock or fire, do the following:**

1. Where possible and safe to do so, the electrician who identifies the issue should take immediate action necessary to prevent an accident. This may include disconnecting a circuit that has exposed live parts that are accessible or restricting access to that location.
2. Report the issue to the owner or person in control of the installation as soon as practicable and discuss what work is needed to either rectify the issue or make the installation safe.
3. If the owner agrees to this, perform the agreed actions. Document what you have done and provide the owner with a copy of this record. No further reporting to CBOS is required.
4. If the owner will not allow you to take action, record the identified issues in writing and provide a copy to the owner. Then report the issue to CBOS as soon as possible. Email [cbos.info@justice.tas.gov.au](mailto:cbos.info@justice.tas.gov.au) and provide the following details:
  - a. The site address, occupant's name and contact details,
  - b. A description of the safety issue and the date it was identified, your actions taken, and
  - c. Name, licence number and contact details of the electrical practitioner who identified the issue, and of the person making the report.

### **If there is no immediate risk of electric shock or fire, do the following:**

1. Report the issue to the owner of the installation as soon as practicable and discuss what work needs to occur.
2. If the owner agrees to this, perform the agreed actions, document what you have done and provide the owner with a copy of this record.
3. If the owner disagrees, then record the identified issues in writing and provide a copy to the owner. No further action is necessary.

## Document Development History

Version	Application Date	Sections amended
00	July 2021	Original release

This document has been produced and published by the Consumer, Building and Occupational Services Division of the Department of Justice. Although every care has been taken in the production of the work, no responsibility is accepted for the accuracy, completeness, or relevance to the user's purpose, of the information. Those using it for whatever purpose are advised to verify it with the relevant government department, local government body or other source and to obtain any appropriate professional advice. The Crown, its officers, employees and agents do not accept liability however arising, including liability for negligence, for any loss resulting from the use of or reliance upon the information and/or reliance on its availability at any time.

For office use only DOC/21/49203 Published July 2021